

CICC Safety Announcement

Electrical Safety Violations

CICC SAFETY NEWS FLASH

The following are electrical violations seen in the field in the past quarter; violations that may have resulted in an OSHA Citation(s).

- Electrical panel blocked
- Permanent use of temporary wiring
- Electrical panel with open holes
- Outlet box in need of repair
- Weld rod over box with a bare cord
- Using household surge protector on the shop
- Extension cord has no ground prong or strain relief – 5 separate violations
- Bad cords are cut and coming apart
- Electrical panel is open and exposed on the loading dock
- Cord is coming apart
- Temporary electrical box needs to be secured
- Temporary light socket is open
- Wall outlet has not cover
- One bad cord with no ground prong on drop light
- Outlet box that needs to be repaired
- Cord in need of repair
- Permanent use of temporary wiring
- Extension cord has significant damage and no strain relief
- One bad cord was coming apart
- Bad Extension cord on torch cord

These hazards can cause injury to one of your employees and may subject you to OSHA fines. Please take a moment to review your overall operations to enhance your electrical safety program. This topic will be addressed in further detail at the next Claim & Loss Control Committee Meeting in October 2006.

[Learn more...](#)

Meadowbrook/TPA Associates

Carol DiPietro

VP Business Development

email: [carol.](mailto:carol.dipietro@meadowbrook.com)

dipietro@meadowbrook.com

phone: 978-691-2470 x115

Loss Control Department

William O'Connell

Loss Control Specialist

email: [william.](mailto:william.oconnell@meadowbrook.com)

oconnell@meadowbrook.com

phone: 978-691-2470 x119

[Forward email](#)

 **SafeUnsubscribe™**

This email was sent to jonathan.claflin@meadowbrook.com, by [carol.dipietro@meadowbrook.com](#)

[Update Profile/Email Address](#) | Instant removal with [SafeUnsubscribe™](#) | [Privacy Policy](#).

Powered by



Meadowbrook/TPA | 10 New England Business Center | Andover | MA | 01810